

# Emission Test Certificate

Tuesday, February 26, 2013

Supplier: Permaform Australia (66 Hawdon St, Ainslee, ACT, 2620)

Sample Description: Permaform

Date Tested: February 2013


Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V1.1 IEQ-11</b>	<b>Permaform</b>
Total Volatile Organic Compound emission rate $<0.5 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound emission rate $0.225 \text{ mg/m}^2/\text{hr}$



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc  
Consultant

CV130219