THE MARRON CONSULTANCY

ABN 96 276 451 253 4/168 Beecroft Road, Cheltenham, NSW 2119 Phone/Fax +61 2 9868 5351 — Mobile 0408 335 558 Email: crawd@bigpond.net.au

CERTIFICATE


Date: 30 October 2016

Client: Auswood International Pty Ltd Unit 6, 4-20 Violet St, Revesby, NSW 2212

Project: Adjustable steel props

Preliminary:

Testing was carried out to a test protocol prepared by the undersigned. Tests were carried out by Mahaffey Associates Pty Ltd. Unit 9/108-110 Percival Road, Smithfield, NSW 2164 during October 2016.



The steel prop illustrated has a nominal weight of 21.1 kg with the outer tube being 76 mm OD \times 2.6 mm wall thickness and the inner tube being 63.5 mm OD \times 3.1 mm wall thickness.

Based on three tests carried out and evaluated in accordance with AS 3610, Clause A4.4.4 the rated Working Load Limit (WLL) is 17 kN.

The testing was witnessed by the undersigned and the results are certified to represent the test results.

Andrawba

D. W. Crawford BE (UNSW), ASTC, MIEAust, NER, RPEQ